



**RAIL BRACKETS**

TABLE 1	RAIL FORCES	
*R1	*R2	
500 lbf	1570 lbf	
RAIL WEIGHT:		80 lbs / ft



FOR TOTAL PULL-OUT FORCE ON RAIL BRACKET,  
eq 2 x 720 = 1440 lbf  
FOR LOCAL APPLICATION OF PIT LOAD,  
R1 MUST BE DOUBLED.



**TABLE 2**

PIT RE-ACTION FORCE	8000 LBS
R3	8000 LBS
R4	3000 LBS
R5	9500 LBS

**LOADS ON PIT**



**TABLE 3**

DISCONNECT	TIME DELAY	VOLTS	PHASE	FLA
MOTOR & EQUIP	30 AMPS	E08 volt	Three Phase	88.9 AMPS
MOTOR & EQUIP	40 AMPS	E20 volt	Single Phase	35.0 AMPS
CAB LIGHTS	15 AMPS	115 V	Single Phase	

**PROVISIONS BY OTHERS**

**\*GENERAL**

**HOISTWAY**– THE HOISTWAY MUST BE IN ACCORDANCE WITH SAFETY CODE FOR ELEVATORS AND ESCALATORS (ASME A17.1) AND BE PROVIDED WITH A MINIMUM CLEARANCE OF 6'6" (1981mm) FROM THE HOISTWAY TO THE CEILING. CLEARANCE FROM THE HOISTWAY TO THE CEILING RUNNING CLEARANCE DIMENSION MUST ENSURE THAT HOISTWAY AND PIT (WHERE PROVIDED) ARE LEVEL, PLUMB AND SQUARE AND ARE IN ACCORDANCE WITH THE DIMENSIONS ON THESE DRAWINGS.

**MINIMUM OVERHEAD CLEARANCE**– DIMENSIONS MUST ENSURE MINIMUM OVERHEAD CLEARANCE IS IN COMPLIANCE WITH CODES. CONSTRUCTION SITE– DIMENSIONS TO PROVIDE ALL MASONRY, CARPENTRY AND DRYWALL WORK AS REQUIRED AND SHALL PATCH AND MAKE GOOD INCLUDING FINISH PAINTING) ALL AREAS WHERE WALLS/FLOORS MAY REQUIRE TO BE CUT, DRILLED OR ALTERED IN ANY WAY TO PERMIT THE PROPER INSTALLATION OF THE LIFT.

**DIMENSIONS**– CONTRACTOR/CUSTOMER TO VERIFY ALL DIMENSIONS AND REPORT ANY DISCREPANCIES TO OUR OFFICE IMMEDIATELY.

**\*STRUCTURAL**

**FLOOR/SUPPORT WALL LOADS**– STRUCTURE TO ANCHOR A GRANK SHAF AND SAFETY HARNESS, WHERE APPLICABLE/NEEDED, TO BE PROVIDED BY CONTRACTOR. CONTRACTOR TO ASSURE THAT BUILDING AND SHAF WILL SAFELY SUPPORT ALL LOADS IMPOSED BY THE LIFT EQUIPMENT. REFER TO THE TABLES ON THIS DRAWING FOR LOADS IMPOSED BY THE EQUIPMENT.

**\*MACHINE ROOM (WHERE REQUIRED)**

**LOCATION / ACCESS**– MACHINE ROOM LOCATED AT THE LOWEST LEVEL ADJACENT TO HOISTWAY UNLESS SHOWN OTHERWISE ON THE LAYOUT DRAWINGS. FIELD ADJUSTMENT BY INSTALLER MAY BE NECESSARY TO MEET JOB SITE CONDITIONS OR REGULATIONS. MACHINE ROOM DOOR IS TO BE LOCKABLE AND IS TO MEET THE REQUIREMENTS OF THE AUTHORITY HAVING JURISDICTION.

**SLEEVES FOR ELECTRIC LINES**– FROM MACHINE ROOM TO HOISTWAY AS REQUIRED. POSITION PER INSTALLERS INSTRUCTIONS.

**POWER SUPPLY**– (SEE SPECIFICATIONS) LOCKABLE FUSED DISCONNECT WITH MANUAL CONTROL BREAK THE BATTERY FEED, OR CIRCUIT BREAKER WITH 1/2" ELECTRICAL CODE AS FOLLOWS LOCATED ON WALL ON LOCK JAMB SIDE OF MACHINE ROOM DOOR. PERMANENT POWER– BEFORE INSTALLATION CAN BEGIN, PERMANENT POWER MUST BE SUPPLIED.

**LIGHTING**– THE ILLUMINATION SHALL BE NOT LESS THAN 200 LX (19 FCD) AT THE FLOOR LEVEL IN ALL MACHINE ROOMS AND MACHINERY SPACES. ENSURE AT LEAST 100 LX (10 FCD) AMBIENT LIGHTING OVER LIFT AREA. PHONE– NEED A DEDICATED PHONE LAND LINE

**\*ENTRANCES**

**FASCIA PANEL BELOW UPPER LEVEL ENTRANCE**– WHERE REQUIRED, FASCIA PANEL MUST BE FASTENED TO A SOLID WALL AND BE PERPENDICULAR TO THE FLOOR AND WALLS. HOISTWAY FASCIA IS NOT SELF-SUPPORTING FOR LONG, CONTINUOUS RUNS VOID OF ENTRANCES. ADEQUATE SUPPORT FOR THE FASCIA MUST BE PROVIDED.

**NOTE LIFTING BEAM**– A 400LB MIN SWL BEAM MUST BE PROVIDED IN THE HOISTWAY. THE BEAM SHALL BE PROVIDED IN THE POSITION THE UNDERSIDE OF BEAM AT 104" & BEAM MUST BE TEMPORARY.

**NOTE C**

ALL INFORMATION IS SUBJECT TO CHANGE. PLEASE REFERENCE OUR ON-LINE DRAWINGS AT WWW.SAVARIA.COM FOR THE MOST RECENT UPDATES

**RESIDENTIAL ELEVATOR**

**ZENITH MODEL 36X60 TYPE 3**

CUSTOMER:	DATE:
PROJECT:	ISSUANCE DATE:
LOCATION:	COMPLETED BY: